

ADA TRANSITION PLAN

ADA - BUILDING COMPLIANCE CHECK (PUBLIC ACCESS)

| FACILITY | STREET ADDRESS, CITY | AREA | BARRIER(S) Y/N - ISSUES | SOLUTION | TARGET DATE | ADA TIMELINE | TASK ORDER # | IN PROGRESS/ COMPLETE | EST. COSTS | FUNDING SOURCE | NOTES/PERSON RESPONSIBLE |
|--|---------------------------------------|---------------------|---|----------|-------------|--------------|--------------|-----------------------|------------|----------------|---------------------------------|
| Fixed Facilities | | | | | | | | | | | |
| Dorchester Road Regional Library | 6325 Dorchester Road, N. Charleston | | Consultant Fees - Assesment to create scope and costs. | | | | 47851 | IN PROGRESS | \$1,200.00 | | |
| Otranto Road Regional Library | 2261 Otranto Road, N. Charleston | | Consultant Fees - Assesment to create scope and costs. | | | | 47852 | IN PROGRESS | \$1,200.00 | | |
| Johns Island Regional Library | 3531 Maybank Highway, Johns Island | | Consultant Fees - Assesment to create scope and costs. | | | | 47583 | IN PROGRESS | \$1,200.00 | | |
| Mt Pleasant Regional Library | 1133 Mathis Ferry Road, Mt. Pleasant | | Consultant Fees - Assesment to create scope and costs. | | | | 47854 | IN PROGRESS | \$1,200.00 | | |
| Cooper River Memorial Library | 3503 Rivers Avenue, N. Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | Being replaced within 18 months |
| John L. Dart Library | 1067 King Street, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Edisto Library | 1589 Highway 174, Edisto Island | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Folly Beach Library | 45 Center Street, Folly Beach | | Assessment - Priorities 1 - 4 | | | | | | | | |
| James Island Library | 1248 Camp Road, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | Being replaced within 18 months |
| Main Library | 68 Calhoun Street | | Assessment - Priorities 1 - 4 | | | | | | | | |
| McClellanville Library | 222 Baker Street, McClellanville | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Village Library | 430 Whilden Street, Mt. Pleasant | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Cynthia Graham Hurd / St. Andrews Regional Library | 1735 North Woodmere Drive, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| St. Pauls / Hollywood Library | 5151 Town Council Dr., Hollywood | | Assessment - Priorities 1 - 4 | | | | | | | | Being replaced within 18 months |
| Edgar Allen Poe / Sullivan's Island Library | 1921 Ion Avenue, Sullivans Island | | Assessment - Priorities 1 - 4 | | | | | | | | |
| West Ashley Library | 45 Windermere Blvd., Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Charleston Center - DAODAS | 5 Charleston Center Drive | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Emerency Service Building | 8500 Palmetto Commerce Parkway | | Assessment - Priorities 1 - 4 | | | | | | | | Address confirmed - DJM |
| Lonnie Hamilton III PSB | 4045 Bridge View Drive | | Assessment - Priorities 1 - 4 | | | | | | | | |
| | | 1. Main Entry Doors | Left ADA assessible door will not stay open. Repair/replace door closure. (Priority #1) | | | | 48440 | IN PROGRESS | \$3,240.00 | | |
| Law Enforcement Center - Admin Bldg 100 | 3691 Leeds Avenue | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Law Enforcement Center - Operations Bldg 200 | 3691 Leeds Avenue | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Detention Center - Leeds Ave | 3841 Leeds Ave. | | Assessment - Priorities 1 - 4 | | | | | | | | |

| ADA TRANSITION PLAN | | | | | | | | | | | |
|---|----------------------|----------------------|--|---|----------------------------|--------------|--------------|-----------------------|------------|----------------|---------------------------------|
| ADA - BUILDING COMPLIANCE CHECK (PUBLIC ACCESS) | | | | | | | | | | | |
| FACILITY | STREET ADDRESS, CITY | AREA | BARRIER(S) Y/N - ISSUES | SOLUTION | TARGET DATE | ADA TIMELINE | TASK ORDER # | IN PROGRESS/ COMPLETE | EST. COSTS | FUNDING SOURCE | NOTES/PERSON RESPONSIBLE |
| Juvenile Detention | 4350 Headquarters Rd | | Assessment - Priorities 1 - 4 | | | | | | | | Being replaced within 18 months |
| Work Camp | 3887 Leeds Ave. | | Assessment -Complete | | | | | IN PROGRESS | | | |
| | | Parking lot/entrance | Priority 1- Approach and Entrance Barrier | Priority 1- Parking signage has to be raised to 60" | Before January 2020 | 1 | | | \$200.00 | operations | Don Crabtree |
| | | Parking lot/entrance | Priority 1- Approach and Entrance Barrier | Priority 1- Regrade built up curb ramp to proper grade | Before January 2020 | 1 | | | \$1,000.00 | improvement | Don Crabtree |
| | | Parking lot/entrance | Priority 1- Approach and Entrance Barrier | Priority 1- Install Accessible symbol signage at entrances | Before January 2020 | 1 | | | \$300.00 | operations | Don Crabtree |
| | | Parking lot/entrance | Priority 1- Approach and Entrance Barrier | Priority 1- Adjust/replace entrance door closures(time and force) | Before January 2020 | 1 | | | \$600.00 | operations | Don Crabtree |
| | | Shelter areas | Priority 2- Access to Goods and Services Barrier | Priority 2- Rearrange picnic tables to allow 36in. access | Before January 2020 | 1 | | | no cost | operations | Don Crabtree |
| | | Shelter areas | Priority 2- Access to Goods and Services Barrier | Priority 2- Relocate TV's(2) from circulation paths | January 2020-December 2021 | 2 | | | \$2,000.00 | improvement | Don Crabtree |
| | | Shelter areas | Priority 2- Access to Goods and Services Barrier | Priority 2- Remove/relocate sick call box from circulation path | Before January 2020 | 1 | | | \$50.00 | operations | Don Crabtree |
| | | Shelter areas | Priority 2- Access to Goods and Services Barrier | Priority 2- Replace signage with tactile/braille and placement | Before January 2020 | 1 | | | \$600.00 | operations | Don Crabtree |
| | | Shelter areas | Priority 2- Access to Goods and Services Barrier | Priority 2- Reconfigure exam bed to provide clearance | Before January 2020 | 1 | | | no cost | operations | Don Crabtree |
| | | Shelter areas | Priority 2- Access to Goods and Services Barrier | Priority 2- Adjust/replace interior door closures(time and force) | Before January 2020 | 1 | | | \$3,000.00 | improvement | Don Crabtree |
| | | Shelter areas | Priority 2- Access to Goods and Services Barrier | Priority 2- provide(2) ADA compliant options for dining | January 2020-December 2021 | 2 | | | \$2,000.00 | improvement | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Replace restroom signage with tactile/braille and placement | Before January 2020 | 1 | | | \$200.00 | operations | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Install new handle (proper height) on female restroom | Before January 2020 | 1 | | | \$50.00 | operations | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Adjust/replace restroom door closures(time and force) | Before January 2020 | 1 | | | \$600.00 | operations | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Modify(2) sink & counter to provide ADA compliant option | January 2022-December 2023 | 3 | | | \$5,000.00 | improvement | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Install ADA compliant faucet on ADA compliant sinks | January 2022-December 2023 | 3 | | | \$300.00 | operations | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Install ADA accessible soap and towel dispensers | Before January 2020 | 1 | | | \$150.00 | operations | Don Crabtree |

ADA TRANSITION PLAN

ADA - BUILDING COMPLIANCE CHECK (PUBLIC ACCESS)

| FACILITY | STREET ADDRESS, CITY | AREA | BARRIER(S) Y/N - ISSUES | SOLUTION | TARGET DATE | ADA TIMELINE | TASK ORDER # | IN PROGRESS/ COMPLETE | EST. COSTS | FUNDING SOURCE | NOTES/PERSON RESPONSIBLE |
|------------------------|----------------------|----------------------|--|---|----------------------------|--------------|--------------|-----------------------|--------------------|----------------|--------------------------|
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Renovate ADA Accessible water closets(2) to provide clearance | January 2022-December 2023 | 3 | | | \$20,000.00 | improvement | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Install proper side and rear grab bars at ADA waterclosets | January 2022-December 2023 | 3 | | | \$800.00 | operations | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Replace flush valves on ADA waterclosets | January 2022-December 2023 | 3 | | | \$800.00 | operations | Don Crabtree |
| | | Shelter areas | Priority 4- Additional Access Barrier | Priority 4- Replace (4)water fountains with ADA accessible units | January 2020-December 2021 | 2 | | | \$6,000.00 | improvement | Don Crabtree |
| | | | | | | | | TOTAL | \$43,650.00 | | |
| Bond/Preliminary Court | 3841 Leeds Ave. | | Assessment - Complete | | | | | IN PROGRESS | | | |
| | | Parking lot/entrance | Priority 1- Approach and Entrance Barrier | Priority 1- Regrade ADA parking areas to less than 1:48 grade | January 2020-December 2021 | 2 | | | \$5,000.00 | improvement | Don Crabtree |
| | | Parking lot/entrance | Priority 1- Approach and Entrance Barrier | Priority 1- Regrade/reconfigure curb ramps to less than 1:12 grade | January 2020-December 2021 | 2 | | | \$2,500.00 | improvement | Don Crabtree |
| | | Parking lot/entrance | Priority 1- Approach and Entrance Barrier | Priority 1- Regrade entrance approach to less than 1:20 grade | January 2020-December 2021 | 2 | | | \$2,500.00 | improvement | Don Crabtree |
| | | Court lobby | Priority 2- Access to Goods and Services Barrier | Priority 2-Lower 1 each service counter to less than 36 inches | January 2020-December 2021 | 2 | | | \$5,000.00 | improvement | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 2- Relocate plant at least 18 inches away from restroom door | Before January 2020 | 1 | | | no cost | operations | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Reconfigure female restroom entrance walls for clearance | January 2020-December 2021 | 2 | | | \$2,500.00 | improvement | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Adjust/replace restroom door closures(time and force) | Before January 2020 | 1 | | | \$600.00 | operations | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Reconfigure privacy walls for proper clearance | January 2020-December 2021 | 2 | | | \$5,000.00 | improvement | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Reconfigure female restroom fixtures, etc for clearance | January 2022-December 2023 | 3 | | | \$10,000.00 | improvement | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Relocate soap dispensers | Before January 2020 | 1 | | | \$100.00 | operations | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Replace(2) rear grab bars with 36 inch length bars | Before January 2020 | 1 | | | \$500.00 | operations | Don Crabtree |

| ADA TRANSITION PLAN | | | | | | | | | | | |
|---|---|----------------------------|---|--|----------------------------|--------------|--------------|-----------------------|--------------------|----------------|--------------------------------|
| ADA - BUILDING COMPLIANCE CHECK (PUBLIC ACCESS) | | | | | | | | | | | |
| FACILITY | STREET ADDRESS, CITY | AREA | BARRIER(S) Y/N - ISSUES | SOLUTION | TARGET DATE | ADA TIMELINE | TASK ORDER # | IN PROGRESS/ COMPLETE | EST. COSTS | FUNDING SOURCE | NOTES/PERSON RESPONSIBLE |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Replace female ADA flush valve with automatic to correct operability | Before January 2020 | 1 | | | \$400.00 | operations | Don Crabtree |
| | | Restrooms | Priority 3- Toilet Rooms Barrier | Priority 3- Reconfigure both restrooms to provide 60 inch approach to ADA stalls | January 2022-December 2023 | 3 | | | \$25,000.00 | improvement | Don Crabtree |
| | | | | | | | | TOTAL | \$59,100.00 | | |
| Pet Friendly Shelter | 3675 Leeds Avenue | | Assessment - Priorities 1 - 4 | | | | | IN PROGRESS | | | |
| | | Toilet Rooms | All bathrooms not ADA compliant. | Update stalls and access, grab bars, counter top heights, new pvc traps and covers, correct faucets, new toilets and dispensers. | 6/19/2019 | 3 | | | \$15,000.00 | improvement | David Sweatte (via contractor) |
| | | Access to goods & services | No Braille signage in hallways and room access. | Install signs | 5/1/2019 | 2 | | | \$800.00 | improvement | David Sweatte (via contractor) |
| | | Parking lot | No van accessible signs. | Install signs | 5/19/2019 | 1 | | | \$800.00 | improvement | David Sweatte (via contractor) |
| | | Hallways | Water fountains not compliant | Install water fountains proper heights | 5/19/2019 | 4 | | | \$600.00 | improvement | David Sweatte (via contractor) |
| | | Hallways | Phone Signage | Add proper phone signage ADA | 5/19/2019 | 4 | | | \$800.00 | improvement | David Sweatte (via contractor) |
| | | | | | | | | TOTAL | \$18,000.00 | | |
| COMING SOON: | | | | | | | | | | | |
| Wando Mt. Pleasant Library | New Library | | Reviewing plans for ADA Compliance | | | | 48751 | IN PROGRESS | \$500.00 | | |
| Baxter-Patrick James Island Library | Replaces James Island Library | | Reviewing plans for ADA Compliance | | | | 48757 | IN PROGRESS | \$500.00 | | |
| R. Keith Summey North Charleston Library | Replaces Copper River Memorial | | Reviewing plans for ADA Compliance | | | | 48754 | IN PROGRESS | \$500.00 | | |
| Bees Ferry Library W. Ashley | New Library | | Reviewing plans for ADA Compliance | | | | | | \$500.00 | | |
| NEW St. Paul's Hollywood Library | Replaces old Hollywood Library Hwy 165 or Toogoodoo Rd. | | Reviewing plans for ADA Compliance | | | | 48756 | IN PROGRESS | \$500.00 | | |
| Juvenile Detention | Building H | | | | | | | | | | |
| | | | | | | | | | | | |
| Buildings | | | | | | | | | | | |
| Building Services | 4305 Bohicket Rd. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Coroner's Office | 4000 Salt Point Rd. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Charleston Heights Shopping Center | 3346 Rivers Ave. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Juvenile Justice | Suite A | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Juvenile Justice | Suite B | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Crisis Stabilization | Suite C | | Assessment - Priorities 1 - 4 | | | | | | | | |
| | Suite D - 1 | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Child Support Enforcement | Suite E | | Assessment - Priorities 1 - 4 | | | | | | | | |

ADA TRANSITION PLAN

ADA - BUILDING COMPLIANCE CHECK (PUBLIC ACCESS)

| FACILITY | STREET ADDRESS, CITY | AREA | BARRIER(S) Y/N - ISSUES | SOLUTION | TARGET DATE | ADA TIMELINE | TASK ORDER # | IN PROGRESS/ COMPLETE | EST. COSTS | FUNDING SOURCE | NOTES/PERSON RESPONSIBLE |
|---|---|------|-------------------------------|----------|-------------|--------------|--------------|-----------------------|------------|----------------|--------------------------|
| Department of Social Services (Lee Building) | 3366 Rivers Avenue | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Adult Protective Services | 3947 Whipper Barony Ln. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Legal | 2036 Cherokee Ln. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Training | 2036 Cherokee Ln. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Annex | 3360 Rivers Ave. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Elections Commission Headquarters | 4367 Headquarters Rd | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Warehouse/Voter Registration | | | Assessment - Priorities 1 - 4 | | | | | | | | |
| DHEC/HEALTH CLINICS | | | | | | | | | | | |
| East Cooper | 1189 Sweetgrass Basket Pkwy | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Whipper Barony | 3963 Whipper Barony Ln. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Vital Records | Perimeter Center | | Assessment - Priorities 1 - 4 | | | | | | | | |
| MAGISTRATES | | | | | | | | | | | |
| Magistrate/Small Claims/Summary- North Area | 4045 Bridge View Drive, N. Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Magistrate - James Island | 615 Riverland Drive, James Island | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Magistrate - East Cooper | 1189 Sweetgrass Basket Pkwy, Suite 300, Mt. Pl. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Magistrate - Johns Island | 1527 Main Road, Suite 100, Johns Island | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Magistrate/Central Bond, Preliminary Hearing | 3831 Leeds Avenue, Suite 200/100, N. Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Magistrate - McClellanville | 10009 Highway 17 North, McClellanville | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Magistrate - Melbourne | 2145 Melbourne Avenue, Suite 100, N. Chas. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Magistrate - North Area | 6185 Rivers Avenue, Suite E, N. Chas. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Magistrate - Ravenel | 5962 Highway 165; Suite 200, St. Paul, Ravenel | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Magistrate - City Sm Claims | 995 Morrison Drive, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Magistrate - West Ashley | 1720 Sam Rittenburg Ave., Unit 11, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| SERVICE CENTERS | | | | | | | | | | | |

| ADA TRANSITION PLAN | | | | | | | | | | | |
|---|--|------|-------------------------------|----------|-------------|--------------|--------------|-----------------------|------------|----------------|--------------------------|
| ADA - BUILDING COMPLIANCE CHECK (PUBLIC ACCESS) | | | | | | | | | | | |
| FACILITY | STREET ADDRESS, CITY | AREA | BARRIER(S) Y/N - ISSUES | SOLUTION | TARGET DATE | ADA TIMELINE | TASK ORDER # | IN PROGRESS/ COMPLETE | EST. COSTS | FUNDING SOURCE | NOTES/PERSON RESPONSIBLE |
| East Cooper Service Center | 1189 Sweetgrass Basket Pkwy., Mt. Pl. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Geo Tumbleston Service Center | 5962 Highway 165, Ravenel | | Assessment - Priorities 1 - 4 | | | | | | | | |
| CLEMSON EXTENSION | | | | | | | | | | | |
| Senior Citizen's Main Bldg. | 259 Meeting Street, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| SOLID WASTE | | | | | | | | | | | |
| Bees Ferry Landfill | 1344 Bees Ferry Rd., Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Romney Recycle Ctr | 13 Romney Street, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Solid Waste/Litter Control | 4350 Azalea Ave., Bldg. C, N. Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| JUDICIAL | | | | | | | | | | | |
| Judicial Center | 100 Broad Street, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| HISTORIC | | | | | | | | | | | |
| Historic Courthouse | 84 Meeting Street, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| DOWNTOWN COUNTY OFFICE | | | | | | | | | | | |
| County Office Building | 101 Meeting Street, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| AZALEA COMPOUND | | | | | | | | | | | |
| Fleet Admin Office | 4371 Headquarters Rd. | | Assessment - Priorities 1 - 4 | | | | | | | | |
| PARKING GARAGES | | | | | | | | | | | |
| King & Queen Street Parking Garage | 85 Queen Street, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |
| Cumberland Street Garage | 13 Romney Street, Charleston | | Assessment - Priorities 1 - 4 | | | | | | | | |

| ADA TIMELINE |
|----------------------------------|
| 1 = Before January 2020 |
| 2 = January 2020 - December 2021 |
| 3 = January 2022 - December 2023 |
| 4 = January 2024 - December 2025 |
| 5 = after December 2026 |